



County of Riverside
DEPARTMENT OF ENVIRONMENTAL HEALTH

P.O. BOX 7909 • RIVERSIDE, CA 92513-7909

STEVE VAN STOCKUM, DIRECTOR

Date: February 8th, 2018

System No. 3301961

Rancho CA RV Resort Owner Association
PO Box 214
Aguanga CA, 92536

Enclosed is Citation No. 05_63_18C_004 issued to Outdoor Resorts a public water system. Please note that there are certain deadlines associated with this Citation.

Any person who is aggrieved by a Citation issued by the Riverside County LPA may file a petition with the State Water Resources Control Board (State Water Board) for reconsideration of the Citation. Petitions must be received by the State Water Board within 30 calendar days of the issuance of the Citation. The date of issuance is the date when the Riverside County LPA mails or serves a copy of the Citation, whichever occurs first. If the 30th day falls on a Saturday, Sunday, or state holiday, the petition is due the following business day. Petitions must be received by 5:00 p.m. Information regarding filing petitions may be found at:

http://www.waterboards.ca.gov/drinking_water/programs/petitions/index.shtml

If you have any questions regarding this matter, please contact this Department at 951-955-8980

Sincerely,

Daisy E. Ciudad Real, M.P.H., R.E.H.S

Certified Mail: 70173040000085608502



County of Riverside
DEPARTMENT OF ENVIRONMENTAL HEALTH

P.O. BOX 7909 • RIVERSIDE, CA 92513-7909

STEVE VAN STOCKUM, DIRECTOR

**CITATION FOR NONCOMPLIANCE – WATER SYSTEM NO. 3301961
NO. 05_63_18C_004**

Date: February 8th 2018

Re: Outdoor Resorts
System No. 3301961

To: Rancho CA RV Resort Owner Association
PO Box 214
Aguanga, CA 92536

Section 116650, Article 9, Chapter 4, Part 12, Division 104 of the California Health and Safety Code (H&S Code), authorizes the issuance of a citation for failure to comply with the requirements of the California Safe Drinking Water Act, or any regulation, standard, permit order issued there under.

VIOLATION

The Department of Environmental Health (Department), hereby issues a citation to Rancho CA RV Resort Owner Association for the following violations:

Title 22 of the California Code of Regulations (CCR), Section 64432.1. Specifically, Rancho CA RV Owner Association failed to sample Outdoor Resort well # 7 for Nitrate as N in the calendar year 2017. All public water systems using groundwater shall monitor Nitrate as N annually.

CHRONOLOGY OF EVENTS

This is a Non-Transient Non-Community water system serving an RV resort with 593 spaces, a golf course clubhouse, restrooms and a maintenance building. The water system serves the same 25 or more people for at least 6 months of the year. The main wells (Well #7) is 245' deep with an 8" casing and is serviced by a submersible pump. Well # 10 is 215' deep with a 10.75 inch casing. Well #9 is the standby well and is 475' deep with an

18" casing. The standby well is used primarily for irrigation. Well # 11 is pending clearance.

Recent History:

Rancho CA RV Resort Owner Association failed to sample Outdoor Resorts Water System well #7 for Nitrate as N in 2017.

The system was reminded of sampling requirement on 11/2017.

DIRECTIVES

Submit the nitrate results to this Department once you have been notified by the laboratory.

Inform the laboratory to EDT water quality data to the State.

Sample the well for Nitrate as N annually. Failure to comply could result in citations with penalty.

This is considered a monitoring and reporting (M&R) violation and requires public notification utilizing the Tier 3 notification method, which is notification to the consumers. The notification must also be provided in the 2017 CCR. All consumers served by this water system must be notified of this violation, as required in Section 64463.4. The notice must be posted in conspicuous locations throughout the area served by the water system for at least 7 days. The posting must be completed by July 1st, 2018. Submit a Proof of Notification to this Department once the notice has been delivered to your water consumers.

FURTHER ENFORCEMENT ACTION

Failure to comply with this notice and/or failure to comply with Title 22 of the California Code of Regulations may result in an administrative office hearing and assessment of administrative penalties. This Department does not waive any further enforcement action by issuance of this citation.

If you have any questions, please contact this Department at (951) 955-8980.



Daisy Ciudad Real, M.P.H., R.E.H.S
Environmental Health Specialist